



FORT PIERCE UTILITIES AUTHORITY

ANNUAL DRINKING WATER QUALITY REPORT - 2002

Administrative Office (772) 466-1600 — Water Plant (772) 466-1600, Ext. 4390

INTRODUCTION

We are proud to report that the water provided by the Fort Pierce Utilities Authority (FPUA) meets the State of Florida and the United States Environmental Protection Agency's (EPA) regulations. This report is furnished pursuant to the EPA Safe Drinking Water Act (SDWA). Beginning in 1999, all community water systems need to provide customers with an annual report on the quality of their water. FPUA tests for a variety of regulated and unregulated compounds to determine if your drinking water meets the SDWA requirements. Review of the Tables contained in this report will show that your drinking water is of excellent quality. The data presented is from the most recent testing done in accordance with regulations. FPUA Board meetings are conducted on the first and third Tuesday of each month at 4:00 p.m. at 100 N. U. S. 1 (City Hall), Fort Pierce, Florida.

PARA LOS CLIENTES HISPANOS

Este es un reporte importante sobre la calidad de su agua. Si usted no cuenta con alguien que pueda traducirle este reporte, llame a la Division de Asuntos del Consumidor de Fort Pierce Utilities Authority al (772) 466-1600 y con mucho gusto le asistiremos.

SOURCE OF FPUA'S DRINKING WATER

Groundwater, from the Surficial Aquifer (about 100 feet below the surface) and the Floridan Aquifer (about 1000 feet), provides the source of water to all customers. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

FPUA's water treatment plant treats the groundwater and removes contaminants by conventional lime softening, aeration, disinfection, and sand filtration combined with reverse osmosis treatment. In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

IMMUNO-COMPROMISED INDIVIDUALS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

DEFINITIONS

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers a treatment or other requirement which a water system must follow.

CDC – Centers for Disease Control

Contaminant – any substance or matter whether physical, chemical, biological, or radiological.

Cryptosporidium – *Cryptosporidium* is a microscopic organism

that, when ingested, can result in diarrhea, fever and other gastrointestinal symptoms. The FPUA Water System has never detected the presence of this organism. *Cryptosporidium* comes from the waste material of warm-blooded animals and is found in surface waters. Since the FPUA Water System utilizes groundwater wells as the sole source of raw water, the presence of *Cryptosporidium* is not expected to occur.

Maximum Contaminant Level (MCL) – the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health.

TEST RESULTS TABLE KEY (for tables on back)

N/A - Not Applicable

ppb - One Part Per Billion; the equivalent of 1 penny in \$10,000,000.

ppm - One Part Per Million; the equivalent of 1 penny in \$10,000. Same as mg/L (milligrams per Liter).

PCU (Platinum Color Unit) - A measure of color in drinking water.

Y/N - Yes/No

TEST RESULTS TABLES - CONTAMINANTS DETECTED

NOTE: Results in the Level Detected column for radiological contaminants, inorganic contaminants, synthetic organic contaminants including pesticides and herbicides, and volatile organic contaminants are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.

Inorganic Contaminants

<u>Contaminant and Unit of Measurement</u>	<u>Dates of Sampling (mo./yr.)</u>	<u>MCL Violation Y/N</u>	<u>Level Detected</u>	<u>Range of Results</u>	<u>MCLG</u>	<u>MCL</u>	<u>Likely Source of Contamination</u>
Barium (ppm)	03/02	N	0.007	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Chromium (ppb)	03/02	N	1.6	N/A	100	100	Discharge from steel and pulp mills; erosion of natural deposits.
Fluoride (ppm)	03/02	N	1.31	N/A	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (as Nitrogen) (ppm)	03/02	N	0.72	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
Nitrite (as Nitrogen) (ppm)	03/02	N	0.04	N/A	1	1	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
Selenium (ppb)	03/02	N	4.4	N/A	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Sodium (ppm) (2001)	03/02	N	68	N/A	N/A	160	Saltwater intrusion: leaching from soil.

Secondary Contaminants

<u>Contaminant and Unit of Measurement</u>	<u>Dates of Sampling (mo./yr.)</u>	<u>MCL Violation Y/N</u>	<u>Level Detected</u>	<u>Range of Results</u>	<u>MCLG</u>	<u>MCL</u>	<u>Likely Source of Contamination</u>
Color (Color Units)	03/02 & 05/02	Y	20*	5 - 20	N/A	15	Naturally occurring organics.

* tested on 03/20/02 - Color has no health effects.

Stage 1 Disinfectant/Disinfection By-Product (D/DBP) Parameters

<u>Contaminant and Unit of Measurement</u>	<u>Dates of Sampling (mo./yr.)</u>	<u>MCL Violation Y/N</u>	<u>Level Detected</u>	<u>Range of Results</u>	<u>MCLG</u>	<u>MCL</u>	<u>Likely Source of Contamination</u>
Total Trihalomethanes (TTHM) (ppb)	01/02 - 12/02	N	10.4	7.3 - 13.4	N/A	80/100	By-product of drinking water chlorination.

Note: The result in the level detected column for TTHMs is the highest of the four quarterly running annual averages of results from all sampling sites.

Lead and Copper (Tap Water)

<u>Contaminant and Unit of Measurement</u>	<u>Dates of sampling (yr.)</u>	<u>AL Violation Y/N</u>	<u>90th Percentile Results</u>	<u>Number of sampling sites exceeding AL</u>	<u>MCLG</u>	<u>AL</u>	<u>Likely Source of Contamination</u>
Copper (tap water) (ppb)	2001	N	0.43	0	1.3	1.3	Corrosion of household plumbing systems.
Lead (tap water) (ppb)	2001	N	10	0	0	15	Corrosion of household plumbing systems.

Microbiological Contaminants

<u>Contaminant and Unit of Measurement</u>	<u>Dates of sampling (mo./yr.)</u>	<u>MCL Violation Y/N</u>	<u>Highest Monthly Number of Positive Samples</u>	<u>MCLG</u>	<u>MCL</u>	<u>Likely Source of Contamination</u>
Total Coliform Bacteria	05/02	N	1*	0	1.3	Naturally present in the environment.

*More than 700 bacteriological samples were collected from the water distribution system during 2002 and tested for Coliform Bacteria.

REMARKS:

1. Additional testing of FPUA's drinking water for more than 90 other contaminants resulted in non detects.
2. FPUA's drinking water system has been in full compliance for lead and copper control since the EPA instituted regulations throughout the United States in 1992.